



Lead and Copper Certified Laboratory Report Form
Submit Online: wqcdcompliance.com/login (preferred); Fax (303) 758-1398
WQCD-B2-Drinking Water CAS
4300 Cherry Creek Drive South; Denver, CO 80246-1530

LCR - Results

Revision: 11/01/2016

Section I (Supplied or Completed by Public Water System)				Section II (Supplied or Completed by Certified Laboratory)			
Public Water System Information				Certified Laboratory Information			
PWSID#: CO0247326		Facility ID: DS001		Laboratory ID: CO015			
System Name: Guffey Charter School				Laboratory Name: Colorado Analytical Laboratory			
Contact Person: Ken Walker			Phone #:	Contact Person: Customer Service		Phone: 303-659-2313	
Comments:				Comments:			

Section III (Supplied or Completed by Public Water System)				Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/20/21	Ken Walker	LCR001	LCR001	9/22/21	9/23/21	210922105-01	Copper	EPA 200.8	1.3	0.001	0.865
							Lead	EPA 200.8	0.015	0.001	BDL
9/20/21	Ken Walker	LCR002	LCR002	9/22/21	9/23/21	210922105-02	Copper	EPA 200.8	1.3	0.001	0.046
							Lead	EPA 200.8	0.015	0.001	BDL
9/20/21	Ken Walker	LCR003	LCR003	9/22/21	9/23/21	210922105-03	Copper	EPA 200.8	1.3	0.001	0.087
							Lead	EPA 200.8	0.015	0.001	0.001
9/20/21	Ken Walker	LCR004	LCR004	9/22/21	9/23/21	210922105-04	Copper	EPA 200.8	1.3	0.001	0.154
							Lead	EPA 200.8	0.015	0.001	0.002
9/20/21	Ken Walker	LCR005	LCR005	9/22/21	9/23/21	210922105-05	Copper	EPA 200.8	1.3	0.001	0.061
							Lead	EPA 200.8	0.015	0.001	BDL

NT: Not Tested
 Lab MRL: Laboratory Minimum Reporting Level
 BDL: Below Laboratory MRL. A less than (<) may also be used.

mg/L: Milligrams per Liter
 AL: Action Level

210922105 Y

1/1

Drinking Water Chain of Custody



Report To Information	Bill To Information (If different from report to)	Project Information
Company Name: <u>Guffey Charter School</u>	Company Name: _____	PWSID: <u>CO0247326</u>
Contact Name: <u>Cheryl Kramp</u>	Contact Name: _____	System Name: <u>Guffey Charter School</u>
Address: <u>1459 Main St.</u>	Address: _____	Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
City: <u>Guffey</u> State: <u>CO</u> Zip: <u>80820</u>	City: _____ State: _____ Zip: _____	Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Phone: <u>719-689-2093</u>	Phone: _____	Task Number (Lab Use Only) CAL Task 210922105 JML
Email: <u>Kwalker@guffeyschool.org</u>	Email: _____	
Sample Collector: <u>Ken Walker</u>	PO Number: _____	
Sample Collector Phone: <u>719-358-0190</u>		

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																				Subcontract Analyses							
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
<u>12/21</u>	<u>8:00am</u>	<u>LCR001</u>	<u>1</u>														<u>X</u>													
<u>12/21</u>	<u>8:00am</u>	<u>LCR002</u>	<u>1</u>														<u>X</u>													
<u>12/21</u>	<u>8:00am</u>	<u>LCR003</u>	<u>1</u>														<u>X</u>													
<u>12/21</u>	<u>8:00am</u>	<u>LCR004</u>	<u>1</u>														<u>X</u>													
<u>12/21</u>	<u>8:00am</u>	<u>LCR005</u>	<u>1</u>														<u>X</u>													

Instructions: _____ C/S Info: _____ Seals Present Yes No Headspace Yes No

Delivered Via: HP C/S Charge Temp. 16 C / Ice N Sample Pres. Yes No

Relinquished By: <u>Cheryl Kramp</u>	Date/Time: <u>9/22/21</u> <u>1404</u>	Received By: <u>[Signature]</u>	Date/Time: <u>9/22/21</u>	Relinquished By: <u>[Signature]</u>	Date/Time: <u>9/22/21</u>	Received By: <u>[Signature]</u>	Date/Time: <u>9/22/21</u>
---	---	------------------------------------	------------------------------	--	------------------------------	------------------------------------	------------------------------